

No. 5/2/MISC/2023-FS/15

Dated: 20-06-2023

Certified that THE DAWN SCHOOL (name of building or premises) located at CHURACHANDPUR, CHURACHANDPUR DISTRICT, MANIPUR (address) comprised of G=1 PUCCA CONSTRUCTION owned/occupied by THE DAWN SCHOOL (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with State Fire Service Rule, and verified by Shri Kh. Pauliansang, Officer-Incharge, Fire Sub-Station, Churachandpur on 15/06/2023 (date of inspection) in the presence of the MS. VANLALRUAT, PRINCIPAL (name and addresses of the Principal/President/Chairman/Secretary or his representative) and that the building/premises is fit for occupancy of class CLASS-I TO CLASS-X with effect from 20/06/2023 for a period of 1(one) year in accordance with rule and subject to compliance of the conditions.

## Conditions for the validity fo Fire Safety Certificate:

- All the fire safety arrangements provided there in shall be maintained in good working 1. condition at all times.
- Any loss of life and property due to non functional fire safety measures shall be at the 2. responsibility of the management.
- Fire fighting training & mock drill exercise shall be organized quarterly/half yearly with 3. intimation of fire service department.
- 4. The trained & fire fighting staff should be available round the clock.
- Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning 5.
- Water source of Fire Fighting purposes be available in the school premises throughout the 6. year.
- All exist provided in the School building shall be kept free from any obstruction. 7.
- 8. First Aid Kits and necessary medicines are readily available in the school.
- 9. Fire/Emergency Telephone numbers shall be displayed on the Notice Board.
- School buildings shall be insured against fire and natural calamities with group insurance of 10. School Pupils obstruction.

Issue on 20/06/2023

Signature with Seal:

Name

: Kh. Pauliansang Fire Sub-Station Churachandpur

Designation

: Officer In-Charge **Fire Sub-Station** 

Churachandpur, Manipur

Churachandput